

# T E S T C E R T I F I C A T E

ST-20-08-13-01

**Product:** HILLMAN LAMINATE FLOORING  
Ambition Collection

**Producer:** SYNCHROWOOD.COM SDN BHD  
LOT 838, JALAN DEMAK LAUT 5  
DEMAK LAUT INDUSTRIAL PARK  
93050 KUCHING, SARAWAK  
MALAYSIA

**Order:** Determination of the resistance against abrasion  
according to EN 13329:2017 Annex E

**Test report:** 2720347


**Test result:**

Property	Result	Classification requirements according to EN 13329:2017 Table 2
Resistance against abrasion according to EN 13329:2017 Annex E	Abrasion class AC4	Classes 21-23 and 31-32 are fulfilled

Dresden, 13/08/2020



Head of laboratory

Engineer in charge