

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

FLO-20-08-13-01

Product: HILLMAN LAMINATE FLOORING
Ambition Collection

Producer: SYNCHROWOOD.COM SDN BHD
LOT 838, JALAN DEMAK LAUT 5
DEMAK LAUT INDUSTRIAL PARK
93050 KUCHING, SARAWAK
MALAYSIA

Order: Determination of the formaldehyde emission
according to the test chamber method EN 717-1:2005 for CE-labelling

Test report: 2720347


Test result:

Property	Results	Declaration according to EN 14041:2008
Formaldehyde emission according to EN 717-1:2005	0.03 ppm (216 h)	class E1

Dresden, 13/08/2020



Head of laboratory

Engineer in charge